




- Manual key reset for electrically operated gas valves
- IP54 protective rating
- 230 V AC 4A maximum load
- Provision for air interlocks and emergency stop buttons (KOB21)
- Remote run output

Application

The KS10 Gas Valve Manual Reset is used to re-instate the electrical supply to a gas valve in a commercial kitchen once the ventilation (both supply and extract) has been proven. The KS10 **does not** check the closure of down stream gas valves. For this application see the G621 Gas Safestart and KS22 Trio Safestart. The KS10 provides an electrical output to a gas valve which will break if either the ventilation stops or the remote emergency stops are pressed. The keyswitch operation provides security against unauthorised operation. Electrical connections should be made as shown below by a qualified electrical engineer.

Dimensions



Terminal block

